

Subcontractor - Cranes & Rigging

| | YES | N/A | LOI OBSERVED |
|-----|--------------------------|--------------------------|--|
| 1. | <input type="checkbox"/> | <input type="checkbox"/> | Equipment Declaration submitted to STR. (Subcontractors) |
| 2. | <input type="checkbox"/> | <input type="checkbox"/> | Written confirmation of required operator qualifications is available |
| 3. | <input type="checkbox"/> | <input type="checkbox"/> | Annual Crane equipment inspection records are current and available at work site |
| 4. | <input type="checkbox"/> | <input type="checkbox"/> | Crane equipment is inspected by a designated competent person daily prior to use |
| 5. | <input type="checkbox"/> | <input type="checkbox"/> | Operator is aware of any overhead commodities such as steam, power, or communication lines |
| 6. | <input type="checkbox"/> | <input type="checkbox"/> | Ground conditions are stable and acceptable |
| 7. | <input type="checkbox"/> | <input type="checkbox"/> | All proximity hazards have been identified and proper controls (i.e: Lock Outs, Barricades / Traffic Cones) are in place |
| 8. | <input type="checkbox"/> | <input type="checkbox"/> | Swing radius of crane is properly guarded or barricaded |
| 9. | <input type="checkbox"/> | <input type="checkbox"/> | Rigging personnel are familiar with rigging equipment capacities, limitations, and proper applications |
| 10. | <input type="checkbox"/> | <input type="checkbox"/> | Rigging equipment and devices are inspected prior to use |
| 11. | <input type="checkbox"/> | <input type="checkbox"/> | Portable lifting devices (hoist, come-a-longs, etc) are inspected prior to each use |
| 12. | <input type="checkbox"/> | <input type="checkbox"/> | Defective rigging and lifting devices are promptly removed from service |
| 13. | <input type="checkbox"/> | <input type="checkbox"/> | Forklift rigging or lifting attachments (e.g: Choker Hooks, Rigging Booms,etc.) are approved by the manufacturer and include applicable load chart information |
| 14. | <input type="checkbox"/> | <input type="checkbox"/> | Below the hook lifting devices are designed by a qualified engineer and visibly marked with required information (ie; capacity, weight, manufacturer ID) |
| 15. | <input type="checkbox"/> | <input type="checkbox"/> | Tag lines are used to control loads where necessary |
| 16. | <input type="checkbox"/> | <input type="checkbox"/> | Personnel stay out from underneath suspended loads and maintain safe distances away from swing paths |
| 17. | <input type="checkbox"/> | <input type="checkbox"/> | Critical lift plans (when applicable) are used and available at the work site |

Comments:

| |
|--|
| |
| |
| |
| |

Contractor: _____

P.O. Number: _____

Area/Location: _____

Project No: _____

Print Name_____
Signature_____
Date